

Southern Nevada Building Officials

Southern Nevada Building
Officials
c/o City of Henderson
Building & Fire Safety Dept
240 Water Street
Henderson, NV 89015

Phone: 702-267-3611
Fax: 702-267-3605
Email: [Michael.Bouse@
cityofhenderson.com](mailto:Michael.Bouse@cityofhenderson.com)

MEMBERS

Michael Bouse, Chair
City of Henderson

Phil Coggins
City of North Las Vegas

Ron Nybo
City of Boulder City

Ron Lynn
Clark County

Kurt Sawyer
City of Mesquite

Brent Steed
Pahrump Valley

Paul Wilkins
City of Las Vegas

Lisa Conner
Clark County School District

April 30, 2007

Mr. Eric Borsting
Vice President, Operations
ConSol
7407 Tam O'Shanter Drive
Stockton, CA 95210-3370

RE: MICROPAS Version 7.30

Dear Mr. Borsting,

Thank you for your letter of April 3, 2007 regarding certification of MICROPAS Version 7.30 for use in residential energy calculations in Southern Nevada.

Based upon the technical review of MICROPAS Version 7.30 software developed by Enercomp, Inc. by Consol as presented in your certification letter of April 3, 2007, the building officials from Boulder City, Clark County, Henderson, Las Vegas and North Las Vegas have approved MICROPAS Version 7.30 as an acceptable program for demonstrating compliant designs based upon the 2006 IECC® and the 2006 Southern Nevada IECC Amendments subject to the following recommended use criteria:

1. Have error message in software when:
 - a. Duct insulation is less than R-6.0- in unconditioned space;
 - b. Setback Thermostat is selected
2. Capability to run HERS Ratings for above code compliance (i.e. Energy Star or other building energy savings program).

I trust this information will be of service to you. Should you have any questions or require additional information, please do not hesitate to contact me at (702) 267-3611.

Sincerely,

A handwritten signature in black ink that reads "Michael Bouse". The signature is written in a cursive style with a large initial 'M'.

Michael Bouse
Chairman

cc: SNBO Building Officials
Connie Suckling, Southern Nevada Home Builders
Mr. Ken Nittler, P.E., Enercomp, Inc., 1721 Arroyo Drive,
Auburn, CA 95603-9431